



Registrazione numero/Registration number

PED/0497/2225a/12

CERTIFICATO DI ESAME UE DEL TIPO - PRODUZIONE

EU-TYPE EXAMINATION CERTIFICATE - PRODUCTION

Visto il Fascicolo Tecnico/Referring to the Technical File
n° 228a/12 del/dated 28/03/2017

si certifica che la Società/we certify that the Company

GECA s.r.l.

Via E. Fermi, 98 – 25064 GUSSAGO (BS) – ITALY

ha progettato e costruito l' Attrezzatura a Pressione sotto descritta in conformità con i Requisiti
Essenziali di Sicurezza dell' Allegato I e le Procedure del Modulo B Tipo di Produzione –
Allegato III della Direttiva 2014/68/UE

*has designed and built the following Pressure Equipment in accordance with the Essential Safety
Requirements - Annex I and with the Procedures of Module B Production Type - Annex III of the 2014/68/EU
Directive*

REGOLATORI GAS CON MEMBRANA DI SICUREZZA – CON / SENZA FILTRO – SERIE RG

GAS GOVERNORS WITH SAFETY DIAPHRAGM – WITH / WITHOUT FILTER – SERIES RG

RGxxx, RGxxx-HC, RGxxx-FT, RGxxx-HC-FT, RGxxx-TPIO, RGxxx-HC-TPIO, RGxxx-FT-TPIO, RGxxx-HC-FT-TPIO.
PS_{min} 0 barg; PS_{max} 0,5 barg; TS_{min} -15 °C; TS_{max} +60 °C

RGxxx-1B, RGxxx-HC-1B, RGxxx-FT-1B, RGxxx-HC-FT-1B, RGxxx-1B-TPIO, RGxxx-HC-1B-TPIO, RGxxx-FT-1B-TPIO,
RGxxx-HC-FT-1B-TPIO.
PS_{min} 0 barg; PS_{max} 1,0 barg; TS_{min} -15 °C; TS_{max} +60 °C

RGxxx-1B, RGxxx-HC-2B, RGxxx-FT-2B, RGxxx-HC-FT-2B, RGxxx-2B-TPIO, RGxxx-HC-2B-TPIO, RGxxx-FT-2B-TPIO,
RGxxx-HC-FT-2B-TPIO.
PS_{min} 0 barg; PS_{max} 2,0 barg; TS_{min} -15 °C; TS_{max} +60 °C

DN/ND: 1/2" (DN15), 3/4" (DN20), 1" (DN25), 1"1/4 (DN32), 1"1/2 (DN40), 2" (DN50), DN65, DN80, DN100,
Gruppo Fluido/Fluid Group 1 - Categoria/Category IV

22/03/2012

Prima emissione
First issue

22/03/2022

Rinnovo
Renewal

Ultima emissione
Latest issue

21/03/2032

Scadenza
Expiry



PRD N° 032B

Signatory of EA, IAF and ILAC
Mutual Recognition Agreement

Ing. P.
Fumagalli
B. A. Product

pag. 1/1

GQ002 REV.00