



CERTIFICATE OF QUALITY SYSTEM APPROVAL

N° UKCA-0041-PESR-H-CPF 001-22-ITA

Bureau Veritas UK Ltd, acting within the scope of its notification (UK Approved Body number 0041), attests that the quality system operated by the manufacturer for design, manufacture, final product inspection and testing of the pressure equipment identified hereunder has been examined against the provisions of schedule 1A, module H, of the Pressure Equipment (Safety) Regulations 2016, UK Statutory Instruments 2016 No. 1105, and amendments, and found to satisfy the provisions of the regulation which apply to it.

Manufacturer (Name):	CPF INDUSTRIALE Srl
Address:	Via fermi,98 25064 Gussago (Brescia) Italy
Trading Name - Mark:	CPF
Equipment description:	Valves with safety devices for Fire Extinguishers
Identification of equipment concerned (or list on the back or attached where necessary):	See next page
Existence of an annex to the certificate	N.A.

This certificate will expire on (dd/mm/yyyy): 21/04/2025

The approval is conditional upon the surveillance audits, visits, tests and verifications to be carried out by the local Bureau Veritas entity that entered into a contract with the manufacturer, pursuant to the provisions of such contract.

This certificate shall be deemed to be void and the manufacturer shall alone bear any consequences pursuant to its use, where the manufacturer fails to comply with his undertakings as per the agreement in respect of (a) implementation of the approved quality system and (b) inspection and tests on the final product, and generally where the manufacturer fails in particular to comply with any of his obligations under Pressure Equipment (Safety) Regulations 2016, UK Statutory Instruments 2016 No. 1105, and amendments.

Made at	On (dd/mm/yyyy)	Approved and Recorded in	Signed by	Signature authorised by UK Approved Body No 0041
Milan	22/04/2022	United Kingdom	ALBERTO SODI	<i>Alberto Sodi</i>
Registration Code: 2022/000020/UKCA-0041-PESR				

The present document is subject to the terms of General Conditions of Service attached to the agreement signed by the applicant.
The present document shall not be reproduced, except by the manufacturer in compliance with the provisions of the contract entered into between the local Bureau Veritas entity and the manufacturer.



N° UKCA-0041-PESR-H-CPF 001-22-ITA

List of the concerned equipment

Valve Type	Model(S)	Code
Brass Valves for CO2 Fire Extinguishers PS: 250 bar ; TS -30°C/+60°C	with Bursting Disk (set pressure 185 bar; 195 bar ; 250 bar)	60.2.090.xxxx (from 0001 to 1000)
		60.2.190.xxxx (from 0001 to 1000)

Remarks: All above products are in category III and are marked with UKCA0041